



NOTES:

1. 35E coils are shipped from the factory attached to the unit discharge. Coil discharge is configured for slip and drive field ductwork installation. Coil section is uninsulated. Coils are not for steam applications.
2. CONNECTION TUBING – 0.032-in. thick copper, male solder connection. Refer to connection diameter shown in the table below.
3. COIL CASING – 20-gage galvanized steel
4. COIL TUBING – 1/2 in. OD x 0.016-in. thick copper
5. COIL FINS – 0.0045-in. thick aluminum, 10 per inch, mechanically bonded to tubing.
6. COILS ACCESSORIES – optional air vent and drain
7. Unit dimensions given in inches

35E UNIT SIZE	NO. OF ROWS IN COILS	H	W	Lc	A	B	C	WATER CONN (OD)
04, 05, 06	1 Row	8	12	5	3	6 1/4	-	1/2
	2 Row	8	12	5	4 1/4	6 7/8	1 1/8	7/8
	3 Row	8	12	7 1/4	4 1/4	6 7/8	2 1/8	7/8
	4 Row	8	12	7 1/4	4 1/4	6 7/8	3 1/4	7/8
07, 08	1 Row	10	12	5	3	8 3/4	-	1/2
	2 Row	10	12	5	4 1/4	9	1 1/8	7/8
	3 Row	10	12	7 1/4	4 1/4	9	2 1/8	7/8
	4 Row	10	12	7 1/4	4 1/4	9	3 1/4	7/8
09, 10	1 Row	12 1/2	14	5	4 1/4	10 7/8	1 1/4	7/8
	2 Row	12 1/2	14	5	4 1/4	11 1/2	1 1/8	7/8
	3 Row	12 1/2	14	7 1/4	4 1/4	10 1/4	2 1/8	7/8
	4 Row	12 1/2	14	7 1/4	4 1/4	10 1/4	3 1/4	7/8
12	1 Row	15	16	5	4 1/4	13 3/4	1 1/4	7/8
	2 Row	15	16	5	4 1/4	13 3/4	1 1/8	7/8
	3 Row	15	16	7 1/4	4 1/4	14	2 1/8	7/8
	4 Row	15	16	7 1/4	4 1/4	14	3 1/4	7/8
14	1 Row	17 1/2	20	7 1/2	4 1/4	15 7/8	1 1/4	7/8
	2 Row	17 1/2	20	7 1/2	4 1/4	16 1/2	1 1/8	7/8
	3 Row	17 1/2	20	9 3/4	4 1/4	14	2 1/8	7/8
	4 Row	17 1/2	20	9 3/4	4 1/4	14	3 1/4	7/8
16	1 Row	18	24	7 1/2	4 1/4	15 7/8	1 1/4	7/8
	2 Row	18	24	7 1/2	4 1/4	16 1/2	1 1/8	7/8
	3 Row	18	24	9 3/4	4 1/4	14	2 1/8	7/8
	4 Row	18	24	9 3/4	4 1/4	14	3 1/4	7/8
22	1 Row	18	38	5	3 5/8	15 7/8	1 5/16	7/8
	2 Row	18	38	5	3 5/8	16 1/2	1 3/32	7/8
	3 Row	18	38	7 1/4	3 5/8	14	2 5/32	7/8
	4 Row	18	38	7 1/4	3 5/8	14	3 1/4	7/8

PRODUCT INFORMATION IS SUBJECT TO CHANGE WITHOUT NOTICE.

04/01/2017

JOB NAME	JOB NUMBER	LOCATION	DRAWING NUMBER
BUYER	BUYER #	REVISION A	SHEET 1 OF 1
			35E-202-7