

# Refrigerant Holding Charge Notification

**NOTE:** Read the entire installation instruction manual before starting installation for the units listed in this notification.

The data in this supplement details the R-410A refrigerant holding charge (shipping charge) for CAS Air Cooled Condensing Units produced on or after 04/01/2015. This notification supersedes the Shipping Charge data listed in the Physical Data tables found in the current documentation for these units.

## 60 Hz

CAS	CAS072*A/B	CAS091*A/B	CAS091*G/H	CAS121*A/B	CAS151*A/B	CAS181*A/B	CAS241*A/B
<b>Refrigeration System</b>							
<b># Circuits / # Comp. / Type</b>	1 / 1 / Scroll	1 / 1 / Scroll	1 / 1 / Scroll	1 / 1 / Scroll	1 / 1 / Scroll	1 / 2 / Scroll	1 / 2 / Scroll
<b>R-410A shipping charge, lbs</b>	9.0	9.0	9.0	9.0	9.0	9.0	9.0
<b>System charge w/ fan coil<sup>a</sup>, lbs</b>	14.0	17.0	18.0	20.0	43.0	43.0	38.0

CAS	CAS120*D/E	CAS150*D/E	CAS180*D/E	CAS240*D/E
<b>Refrigeration System</b>				
<b># Circuits / # Comp. / Type</b>	2 / 2 / Scroll	2 / 2 / Scroll	2 / 2 / Scroll	2 / 2 / Scroll
<b>R-410A shipping charge A/B, lbs</b>	9.0 / 9.0	9.0 / 9.0	9.0 / 9.0	9.0 / 9.0
<b>System charge w/ fan coil<sup>a</sup>, lbs</b>	11.0 / 11.0	22.0 / 22.0	22.0 / 22.0	19.0 / 19.0

<sup>a</sup> Approximate system charge with about 25 ft piping of sizes indicated with matched FAS.